

City of Bellevue Local Limits (mg/l)

Pollutant	Existing
Arsenic	0.39
Cadmium	0.047
Chromium, total	1.36
Chromium, hexavalent	No Limit
Copper	0.15
Cyanide	0.01
Lead	0.01
Mercury	0.067
Molybdenum	No Limit
Nickel	0.617
Selenium	No Limit
Silver	No Limit
Zinc	0.988
Phosphorous	No Limit
Total Filterable Residue	2500
Oil and Grease	50

Effective 6/12/2025